

Date : 01/05/2021

**Stability Certificate and plan for the School Building in
DELTA PUBLIC SCHOOL
(ANNALAR EDUCATIONAL TRUST)**

Old T.S.NO:142 &143/1, New T.S.No:5,6/1, Ward No:B, Block No:12, at
Panagaatangudi, Letchumangudi Village, Thiruvarur Main Road, Koothanallur
Municipality & Taluk, Thiruvarur District.

SL No.	Building	Accommodation	Others	Remarks
1.	Principal Room, Staff Room, Office Room, Reception, Class Rooms & Toilets etc.,	600	-	-
	TOTAL	600	-	-

TO WHOM SO EVER IT MAY CONCERN

I certify that all the building and structures including compound wall/ Fence in the campus of Old T.S.NO:142 &143/1, New T.S.No:5,6/1, Ward No:B, Block No:12, at Panagaatangudi, Letchumangudi Village, Thiruvarur Main Road, koothanallur Municipality & Taluk, Thiruvarur District. have been covered by the stability certificate issued on **01.05.2021** For three 01.05.2021 to 30.04.2024

And also certified that no structure in the building / school campus used or unused which is not safe for the children.


Er.R. Balamurugan, M.Tech.,
M.Sc.,(Valu.), M.I.E., C.E., FIV.,
Consulting and Chartered Engineer,
Registered Panel Engineer (Class IA)
No.17, (1st Floor), Dr. Abdul Kalam Nagar,
Mannargudi - 614 001.

**STABILITY CERTIFICATE AND PLAN FOR THE SCHOOL BUILDING
IN" DELTA PUBLIC SCHOOL"(ANNALAR EDUCATIONAL TRUST)
OLD T.S.NO:142 &143/1, NEW T.S.NO:5,6/1, WARD NO:B, BLOCK NO:12,
AT PANAGAATANGUDI, LETCHUMANGUDI VILLAGE, THIRUVARUR
MAIN ROAD, KOOZHANALLUR MUNICIPALITY & TALUK,
THIRUVARUR DISTRICT.**



Er. R. Balamurugan, M.Tech.,

**Chartered Engineer,
Registered Panel Engineer(Class IA),
Govt. Regd. Valuer
Income Tax & Wealth Tax,
Regd. Valuer in IBBI,
Panel Valuer in Banks,
Cell: 9443350271**

ADDRESS

M/S. BHARAT BUILDERS
No.17, (First Floor), Dr. Abdulkalam Nagar Mannargudi-614001.

Building No: 1

From:
Annalar Educational Trust,
Delta Public School,
Panagaatangudi, Letchumangudi Village,
Thiruvarur Main Road, Koothanallur Municipality,
Koothanallur Taluk, Thiruvarur District.

To:
The Tahsildar,
Koothanallur,

**THE TAMIL NADU PUBLIC BUILDING LICENSING ACT NO.13 OF
1965 THE TAMIL NADU PUBLIC BUILDING LICENCE FOR**

**DELTA PUBLIC SCHOOL
(ANNALAR EDUCATIONAL TRUST)**

I intend / to continue to use the existing building / to use the building not at present used as a public building/ which is situated in the site or plot or Land, Town or Old T.S.NO:142 &143/1, New T.S.No:5,6/1, Ward No:B, Block No:12, at Panagaatangudi, Letchumangudi Village, Thiruvarur Main Road, koothanallur Municipality & Taluk, Thiruvarur. and specified in the statement enclosed as a public building for a period of **Three** From 01.05.2021 to 30.04.2024

The year of construction and the present approximate cost of construction and the purpose for which it is to be used or is being used as public building are also furnished in the statement accompanying the application.

I enclosed achallan for Rs.No.....Dated.....in the prescribed form furnished
I also enclosed a certificate of structural soundness issued by

Er.R. Balamurugan, M.Tech.,
17,(First Floor), Dr. Abdulkalam Nagar,
Mannargudi-614001.
Cell:9443350271.

Registration No: R.C.NO.37524/2017/B1, date 19.09.2019 Thanjavur Collectorate

Class: IA (one A)

(Signature of the Owner / Occupier of the Building)

Enclosure: (i) Statement

(ii)Chellan for Rs.....No.....Dated.....

(iii)Form A,B,C,E & Declaration


Explanation:- Separate application shall be made in respect of each building.

STATEMENT ACCOMPANYING

FORM- A

1. Name of the Building : **Delta Public School(Annalar Educational Trust)**
2. Location :
Door No of the building : Thiruvarur Main Road, Panagaatangudi,
R.S. No. : Old T.S.No:142&143/1, New T.S.No:5,6/1,
Ward No. : Ward No:B, Block No:12,
Name of the Place, it : Letchumangudi Village, Koothanallur Taluk,
Corporation/ Municipality / :Thiruvarur District.
Panchayat Union / Township
Cantonment.
3. Year of construction : G.F-2017,F.F -2019, S.F –work in progress
4. Approximate cost of construction : Rs.7,80,00,000/-
5. Purpose for which the building is being Used or proposed to be used. : Principal Room, Staff Room, office room, Reception,Class rooms & Toilets etc
6. Details of construction of the building (Particulars of the foundation, soil, Specification of the various part under) : R.C.C. Framed Structure
Clay mixed with sand
7. 1. Foundation : C.C 1:5:10 using 40 mm jelly
2. Basement : RCC Column &Footings
3. Superstructure : Brick work in Cement mortar
4. Floor and Roof : Cement Mortar, R.C.C. Roof
8. Period for which License is required : Three Years **01.05.2021 to 30.04.2024**
9. No. of persons to be accommodated :600 Nos

Signature of the Engineer


E.R. Balamurugan, M.Tech.,

M.Sc.,(Valu.), M.I.E., C.E., FIV.,

Consulting and Chartered Engineer,

Registered Panel Engineer (Class IA)

No.17, (1st Floor), Dr. Abdul Kalam Nagar,
Mannargudi - 610 011

10. Certified that no additional or alteration has been made to the existing building or portion of a building for the application has been made. I undertake to obtain a fresh license in case any addition or alteration is made to the existing building. I also undertake to obtain a fresh license on the purpose for which the license was granted for the use of the building or a portion of the originally is changed or altered subsequently.

Date:**01.05.2021**

(Signature of the Owner / Occupier of the Building)

FORM- B

Form of certificate of a structural soundness under sub section (1) of section 4 of the Tamil Nadu Public Building Licensing Act 1965 referred to in Rule 4 of the Tamil Nadu Public Building (Licensing) Rule 1976.

I certify that, I have inspected the building mentioned in the statement and furnished Below its salient technical features.

1. FOUNDATION

- | | | |
|-------|---|------------------------|
| (I) | Depth below ground level | : 1.83M |
| (II) | Nature of Soil met with at
Foundation Level | : Clay mixed with sand |
| (III) | Pressure at Foundation | : 8.20 Ton/sqm |
| (IV) | Probable safe bearing capacity
of the strata at foundation | : 20 Ton/sqm |

2. SUPER STRUCTURES


- | | | |
|------|--|--|
| (I) | Maximum stress in the most critical
Section of Masonry and Concrete | : Column – 220 Ton /sqm
: Concrete – 16.50 Ton/sqm |
| (II) | Nature of Masonry and concrete
and its safe Permissible stress | : CC 1:2:4 using 20mm jelly 500Ton/sqm
: CC 1:5:10 using 40mm Jelly 100 Ton/sqm |

The Structural soundness of the Building has been verified by me with reference to the I.S.I loading standards 875 (latest version) and other relevant Indian standards code of Practice and I declare that the building is structurally sound to be used as a public building for the purpose noted in the statement.

A license may be granted the building for the period from **01.05.2021 to 30.04.2024** three years.

Date: **01.05.2021**

Signature of the Engineer


Er.R. Balamurugan, M.Tech.,
M.Sc.,(Valu.), M.I.E., C.E., FIV.,
Consulting and Chartered Engineer,
Registered Panel Engineer (Class IA)
No.17, (1st Floor), Dr. Abdul Kalam Nagar,
Mannargudi - 614 001.

FORM- C

**STATEMENT ACCOMPANY THE CERTIFICATION OF
STRUCTURAL SOUNDNESS**

1. Location of the Building : **Delta Public School (Annalar Educational Trust)**
Location :
Door No of the building : Thiruvarur Main Road, Panagaatangudi Village,
R.S. No : Old T.S.NO:142&143/1, New T.S.No:5, 6/1
Ward No : Ward No:B, Block No:12
Name of Place : Letchumangudi Village, Koothanallur Taluk,
Thiruvarur District
2. Age of Building : -
3. Number of Storeys : Two Storeyed
4. Short description of structure
Steel R.C.C. framed or
Load bearing masonry : R.C.C Framed Structure
5. Purpose for which the building is
certified for use : Principal Room, Staff Room, Office Room,
Reception, Class Rooms& Toilets etc.,
6. The Period for which the building
will be structurally sound : 80 Years
7. No. of persons to be accommodated : 600 Nos
8. Remarks : Plan enclosed

Registration No: R.C.NO.37524/2017/B1, date 19.09.2019 Thanjavur Collectorate

Class: IA (one A)

Date:01.05.2021

Signature of the Engineer


Er.R. Balamurugan, M.Tech.,
M.Sc.,(Valu.), M.I.E., C.E., FIV.,
Consulting and Chartered Engineer,
Registered Panel Engineer (Class IA)
No.17, (1st Floor), Dr. Abdul Kalam Nagar,
Mannargudi - 614 001.


FORM- E

Form of Report to be made to the competent authority by inspecting authority the officers appointed under other Acts Section 28 of the Madras Public Building (Licensing) Act 1965 (Madras Act 13 of 1965) referred to in Rule 7 of the Madras Public Building (Licensing) Rules 1966.

1. Name & Designation of the Inspecting authority (or) officer Appointed or having jurisdiction Under any other Act of Law. : **Er.R.Balamurugan, M.Tech.,**
M.I.E., C.E., FIV.,
No.16, Anbu Nagar 1st Street
Pookkara vilar road,
Thanjavur.Cell:- 9443350271
2. Location of the Building : **Delta Public School(Annalar Educational Trust)**
Location :
Door No of the building : Thiruvarur Main Road, Panagaatangudi Village,
R.S. No. : Old T.S. No:142& 143/1, New T.S.NO:5, 6/1
Ward No. : Ward - B, Block No:12,
Name of Place : Letchumangudi Village, Koothanallur Taluk,
Thiruvarur Dt.
3. Date of Inspection :28.04.2021
4. Purpose for which the Building is used : Principal Room, Staff Room, Office Room,
Reception, Class Rooms & Toilets.,
5. Nature of defects noticed : Nil
6. Suggestions for rectifying the defects: Not applicable
7. If in dangerous condition immediate: Not applicable
Action recommended to be taken

Date:01.05.2021

Signature of the Engineer



Er.R. Balamurugan, M.Tech.,
M.Sc.,(Valu.), M.I.E., C.E., FIV.,
Consulting and Chartered Engineer,
Reggistered Panel Engineer (Class IA)
No.17, (1st Floor), Dr. Abdul Kalam Nagar,
Mannargudi - 614 001.

DECLARATION

Er. R.BALAMURUGAN, son of **V.RAMACHANDRAN** residing at No.16, Anbu Nagar 1st Street, Pookkara vilar road, Thanjavur. Do hereby declare that I possess the qualification and experience specified in the Table to rule 11 of the Tamil Nadu Public Buildings (License) rules 1965 and also approved in the panel of Private Practicing Engineers under Class IA (One A) R.C.NO.37524/2017/B1, date 19.09.2019 Thanjavur Collectorate for issuing the certificate of structural soundness for the Public buildings covered by the certificate under rule 11 of the Tamil Nadu Public Buildings (Licensing) Act 1965.

Remarks:

1. This certificate does not hold or ensures the responsibility for the stability of the building structure due to Natural Calamities like Earth Quake, Gale Cyclone, Fire and Tsunami.
2. The subsequent addition and alteration of the building should be done only with prior information to the certifying authority.

Signature of the Engineer


Er.R. Balamurugan, M.Tech.,
M.Sc.,(Valu.), M.I.E., C.E., FIV.,
Consulting and Chartered Engineer,
Registered Panel Engineer (Class IA)
No.17, (1st Floor), Dr. Abdul Kalam Nagar,
Mannargudi - 614 001.

Station: Thanjavur

Date:01.05.2021

1. **Name & Address** : Er. R.BALAMURUGAN, M.Tech.,
M.I.E., C.E., FIV.,
H.O.:No.17, Dr.Abdul Kalam Nagar,
Mannargudi.
B.O.:No.16, Anbu Nagar 1st Street,
Pookkara vilar road,
Thanjavur.
2. **Experience** : 22 years of Experiences as Panel Valuer of Banks
& Private Practice as Chartered & Consulting
Engineer and Registered in the Panel of Private
Practicing Engineer from 1997.

PROCEEDING OF THE DISTRICT COLLECTOR, THANJAVUR

PRESENT : THIRU. A.ANNADURAI, I.A.S

R.C.NO.37524/2017/B1


Date:19.09.2019

Sub :	Buildings - Tamil Nadu Public Buildings - (Licensing) Act 1965 - application of Thiru.R.Balamurugan to include his name in the panel of Private practicing Engineer under class IA in Thanjavur District - Ordered.
Ref :	1) Thiru.R.Balamurugan Application Dt: 05.10.2017. 2) Engineer-in-Chief, WRD(i/c), And Chief Engineer (General), PWD, Chennai Lr.No.AEE/TI/AE-2/136473/2019/ Dt.24.06.2019. 3) And other connected records.

+++++++

ORDER:

As per the recommendation of Board of Engineers PWD., Chepuk, Chennai in the reference 2nd cited, Thiru. R.Balamurugan, No.61, Anbu Nagar 1st Street, Pookkara vilar road, Thanjavur is included in the panel of private practicing Engineers under class IA(one A) category in Thanjavur District for the issue of structural soundness Certificate for the public buildings (the cost of which exceeds Rs.50.00 lakhs) under rule 11 of the TamilNadu Public Buildings (Licensing) Act 1965.


**District Collector
Thanjavur.**

To

Thiru. R.Balamurugan,
No.61, Anbu Nagar 1st Street,
Pookkara vilar road, Thanjavur.

81.50
19/9/19

Copy to:

1. Engineer-in-Chief, WRD, (i/c)
And Chief Engineer (General), PWD.,
Chepauk, Chennai-600 005.

2. Superintending Engineer, PWD.,
Buildings (C&M) Circle,
Trichy-1.

